Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 116 Dated: 27.05.2026

It is certified that an inspection team headed by ....Mammit Raj Mishra, Assistant Engineer (Name of Officers with designation) from P.H Sub Division Sitamarhi PHED inspected the ...Brahamdev Public School, Bhavdepur, Riga Road, Sitamarhi (Name & Address of the school) on 26.05.2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no.....116..... dated.27.05.2026 of District Water testing Lab. Sitamarhi (PHED Lab) certified that the Brahamdev Public School, Riga Road (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till One Year

Signature with Seal: Mow 27/05/2026
Name : Mammit Raj Mishra
Designation : Assistant Engineer
Name & Address of the Office / Department : .....

SDO
P.H.SUB DIVISION
SITAMARHI

To
.... Brahamdev Public School
Bhadepur Riga Road, Sitamarhi, 843302
(Name & Address of the Institution)

Note The certificate is to be issued by authorized officer / PHED Lab / local bodies

PUBLIC HEALTH ENGINEERING DEPARTMENT

Water Quality Test Report

Division Name :- P. H. Division, Sitamarhi

District Name : Sitamarhi **Month : May 2026**

Name of School-Brahamdev Public School

Sl. No.	Testing Date	Block	Panchayat	Location	Source	pH	Turb.	Cond.	TDS	TH	Ca	Mg	Cl	Alk	Nitrate	Fe	Bact	Remarks
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	17	18
1	26.05.2026	Riga	Bhavdepur	Riga Road	Submersible	7.30	1.8	325	211	180	46	25	45	188	3.2	0.4	(-ve)	**Safe**
Desirable Limit *						**6.5-8.5**	**1.0**	**-**	**500**	**200**	**75**	**30**	**250**	**200**	**45**	**0.3**	_	
Pesrmissible Limit* in absence source (IS 10500-2012 - 2nd Revision						**NR**	**5.0**	**-**	**2000**	**600**	**200**	**100**	**1000**	**600**	**NR**	1	_	

Note: (1) Drinking Water Specification First Revision -IS:10500:2012,Edition 2.2(2003-09,12,20)(Reaffirmed1993), (2) BDL = Below Detection Limit, (3)NR = No Relaxation, (4) ND = Not Done.

(a) Throughout any year, 95% of the samples should not contain coliform organisms in 100ml, (b) No sample should contain more than 10 coliform organisms per 100ml,

(c) Coliform organisms should not be detected in 100ml of any two consecutive samples.

Copy forwarded for information to: (i) Consultant Water Quality Cell, PHED, Govt.of Bihar, (ii) Director,Water Quality Cell,PHED,Govt.of Bihar, (iii) SLWTL,PHED,Govt.of Bihar.

27/05/26

Chemist
P.H Division Sitamarhi
रसायनज्ञ
जल जाँच प्रयोगशाला
लोक स्वास्थ्य प्रमण्डल
सीतामढ़ी

27/05/2026

Assistant Engineer
P.H Sub Division Sitamarhi
S.D.O.
P.H.SUB DIVISION
SITAMARHI